



Certificate of Service

Completed on: 23 September 2009

Serial No: 225255
Plant No: DU15
Service Period (mths): 3
Start Date: 03/09/2009
Renew Date: 03/09/2010

Client Details: A Sample Ltd
 The Mill
 Leicester
 LE18 4US
 Tel:
 Fax:

Client Contact: A Smith

Service Agreement Details

Equipment: DCE DLM

Location: Silo 2 Flour

Service Visit Details

Engineer: DCW

Equipment Check List	Details of Service	Action			Date Completed
		Required	: ASAP	: Next Visit	
Additional Comments		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Air Lines	In Good Order	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Air Tank	Inspected found to be in good order	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Bags (Single Sleeve Type)	New fitted	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	28-Sep-09
Clamping Bolts	In Good Order	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Controller (Pulse Timer Unit)	Operating Correctly	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Diaphragm Valves	Operating Correctly	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Explosion Relief (Panel Type)	Intact	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Fan Chamber	Inspected and cleaned	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Fan Rotation	Correct	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Fan Vibration	None	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Filter Body	In Good Order	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Filter Readings	4" WG	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Jet Tubes	In Good Order	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Rubber Connections	Intact	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Seals (Door/Bag Frame)	New fitted	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	28-Sep-09
Solenoid Valves	Operating Correctly	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

This service visit report is an accurate record of the service carried out by VAK Conveying systems Ltd

S P Will

